

Generic risk assessment for standard rules set number SR2018 No 8 v1.0
Standard Facility:

mobile plant Specified Generator, Tranche B low risk, base load operation <1 – 2 MW operation after 20/12/2018)

Location:

Applies to all potential locations

Risk assessment carried out by:

Environment Agency

Date:

04-May-18

The scope of the permit and associated rules is defined by the following risk criteria:

- Parameter 1 allows one Tranche B Specified Generator which is a diesel fired engine between <1-2MW
 Parameter 2 Mobile plant may be deployed to a given location in rural and urban areas where background NO₂ has sufficient headroom
 Parameter 3 Minimum stack height of 2 m
 Parameter 4 These rules set emission limit values on releases to air only
 Parameter 5 Background NO₂ concentration at sensitive human receptor less than 31 µg/m³
 Parameter 6 rules specify minimum distances from sensitive receptors (depends on hours of operation)
- Abbreviations:
 SR - Standard Rule
 NO_x - Oxides of nitrogen
 NO₂ - Nitrogen Dioxide
 CO - Carbon Monoxide
 CHP - Combined heat and power
 SR (emissions of substances not controlled by emission limits) - emissions of substances shall not cause pollution...., with appropriate measures:

Data and information				Judgement				Action (by permitting)	
Receptor	Source	Harm	Pathway	Probability of exposure	Consequence	Magnitude of risk	Justification for magnitude	Risk management	Residual risk
What is at risk? What do I wish to protect?	What is the agent or process with potential to cause harm?	What are the harmful consequences if things go wrong?	How might the receptor come into contact with the source?	How likely is this contact?	How severe will the consequences be if this occurs?	What is the overall magnitude of the risk?	On what did I base my judgement?	How can I best manage the risk to reduce the magnitude?	What is the magnitude of the risk after management? (This residual risk will be controlled by Compliance Assessment).
Local human population.	Releases of NO _x	Harm to human health - respiratory irritation and illness.	Air transport then inhalation.	Low	Medium	Medium	There is potential for exposure to anyone living close to the site or at locations where members of the public might be regularly exposed.	Activities shall be managed and operated in accordance with a management system (will include inspection and maintenance of equipment, including engine management systems), point source emissions to air with emission limits for NO _x . Point source emission limits set in Table 3.1 of the rules.	Low
Protected nature conservation sites - SACs, SPAs, Ramsar sites and SSSIs.	Releases of NO _x	Harm to protected site through toxic contamination, nutrient enrichment, disturbance etc.	Air transport and deposition.	Low	Medium	Low	Emissions to air may cause harm to and deterioration of nature conservation sites.	Activities shall be managed and operated in accordance with a management system (will include inspection and maintenance of equipment, including engine management systems), point source emissions to air with emission limits for NO _x . Point source emission limits set in Table 3.1 of the rules.	Low

Notes: Red triangle indicates comment containing supporting information

Yellow columns contain drop down menus that allow automatic evaluation of risk in green column